



PRODUCT-DETAILS

E4.2S 4000 Ekip Dip LI 4p F HR
E4.2S 4000 Ekip Dip LI 4p F HR



General Information	
Extended Product Type	E4.2S 4000 Ekip Dip LI 4p F HR
Product ID	1SDA071831R1
EAN	8015644756819
Catalog Description	E4.2S 4000 Ekip Dip LI 4p F HR
Long Description	C.BREAKER SACE EMAX2 E4.2S 4000 FIXED FOUR-POLE WITH TERMINALS REAR HORIZONTAL AND SOLID-STATE RELEASE IN AC EKIP/DIP-LI R 4000 FITTED WITH: 4 AUXILIARY CONTACT AND C.BREAKER IN POSITION OPEN-CLOSED

ABB EcoSolutions	
ABB EcoSolutions	Yes
ABB Site Meeting Group Waste To Landfill Target	UL 2799 Zero Waste To Landfill Validation available
End Of Life Disassembling Instructions	9AKK108468A2363
Environmental Product Declaration - EPD	9AKK108468A1904 9AKK108468A1910
Recyclability Rate of the	Design for Closing Resource Loops - Standard EN45555 - 79.3 %

Product acc. to EN45555

Material Compliance

REACH Declaration	9AKK108466A1425
RoHS Information	9AKK108466A1424
RoHS Status	Following EU Directive 2011/65/EU and Amendment 2015/863 July 22, 2019
Conflict Minerals Reporting Template (CMRT)	9AKK108467A5658
Toxic Substances Control Act - TSCA	9AKK108467A8326
SCIP	5db9272f-d385-4a4a-a0e6-73274e7613b2 Italy

Environmental

Environmental Information	9AKK108467A6707
---------------------------	-----------------

Ordering

Order Code US and Canada	ZCSWERBA000A000000XX
EAN	8015644756819
Minimum Order Quantity	1 piece
Customs Tariff Number	85362090

Dimensions

Product Net Width	510 mm
Product Net Height	371 mm
Product Net Depth / Length	270 mm
Product Net Weight	70 kg

Container Information

Package Level 1 Units	box 1 piece
Package Level 1 Width	515 mm
Package Level 1 Height	610 mm
Package Level 1 Depth / Length	785 mm
Package Level 1 Gross Weight	77 kg
Package Level 1 EAN	8015644756819

Additional Information

Product Main Type	SACE Emax 2
Product Name	Air Circuit Breaker
Product Type	Air Circuit Breaker
Version	F
CAD Dimensional	1SDH001252R0197

Drawing

Technical

Current Type	AC
Electrical Durability	Ue ≤ 440 V 5000 cycle Ue = 500 ... 690 V 4000 cycle 20 cycles per hour
Mechanical Durability	15000 cycle 60 cycles per hour
Neutral Pole Current ([% I _n])	100 %
Number of Poles	4P
Power Loss	465 W
Rated Current (I _n)	4000 A
Rated Impulse Withstand Voltage (U _{imp})	acc. to IEC 60947-2 12 kV
Rated Insulation Voltage (U _i)	AC 1000 V
Rated Operational Voltage	690 V AC
Rated Service Short-Circuit Breaking Capacity (I _{cs})	(220 V AC) 85 kA (230 V AC) 85 kA (380 V AC) 85 kA (400 V AC) 85 kA (415 V AC) 85 kA (440 V AC) 85 kA (500 V AC) 66 kA (660 V AC) 66 kA (690 V AC) 66 kA
Rated Service Short-Circuit Breaking Capacity, in % of I _{cu} (I _{cs})	100 %
Rated Short-time Withstand Current Low Voltage (I _{cw})	for 1 s 66 kA for 3 s 66 kA
Rated Ultimate Short-Circuit Breaking Capacity (I _{cu})	(400 V AC) 85 kA (415 V AC) 85 kA (440 V AC) 85 kA (500 V AC) 66 kA (525 V AC) 66 kA (690 V AC) 66 kA
Rated Uninterrupted Current (I _u)	4000 A
Rated Voltage (U _r)	690 V
Recommended Screw Driver	Main Circuit M12
Release	Ekip Dip LI
Release Type	EL
Short-Circuit Performance Level	S
Standards	IEC
Sub-type	E4.2
Suitable for IT Networks	Yes, 690V
Terminal Connection Type	Rear flat Horizontal
Terminal Type	Bolt
Tightening Torque	70 N·m

Certificates and Declarations

ATEX Certificate	No certification needed
CSA Certificate	No certification needed
CSA Certificate (Intrinsic Safe)	No certification needed
Data Sheet, Technical Information	1SDC200023D0209
Declaration of Conformity - CE	9AKK106713A5545
UL Certificate	No certification needed
VDE Certificate	No certification needed
Mechanical Drawings	1SDH001001R0100
Wiring Diagram	1SDM000091R0001
Instructions and Manuals	1SDH001000R0002

External Classifications and Standards

ETIM 8	EC000228 - Power circuit-breaker for trafo/generator/installation protection
ETIM 9	EC000228 - Power circuit-breaker for trafo/generator/installation protection
Object Classification Code	Q
WEEE Category	4. Large Equipment (Any External Dimension More Than 50 cm)
eClass	V11.1 : 27370409

Categories

Low Voltage Products and Systems → Circuit Breakers → Air Circuit Breakers → Emax 2

